

<input type="checkbox"/> <input type="checkbox"/>	Are open flames, other flame emitting devices, fire, heat, or any flammable or combustible liquids, gas, charcoal or other cooking devices maintained at least 20 feet away from tent/canopy while open to the public? (Must be approved by Fire Code Official. Operations such as warming of foods and similar operations that use solid flammables, butane or other similar devices which do not pose an ignition hazard, shall be approved).
<input type="checkbox"/> <input type="checkbox"/>	Are areas inside and within 20 feet of the tent maintained clear of all combustible materials or vegetation that could create a fire hazard?
<input type="checkbox"/> <input type="checkbox"/>	Is a detailed site plan and floor plan provided?
<input type="checkbox"/> <input type="checkbox"/>	Is the tent/canopy tied down in accordance to the NC Building Code and the NC Fire Prevention Code?
SECTION III. REQUIRED ATTACHMENTS	
<input type="checkbox"/>	Certificate of Flame Resistance.
<input type="checkbox"/>	Floor plan identifying seating arrangement, means of egress, and any cooking, cooling, heating or electrical equipment.
<input type="checkbox"/>	Site plan showing tent/canopy location with 20 foot separation between other structures, tents, canopies, parked vehicles, open flames, cooking devices. (For the purpose of determining required distances, support ropes should be considered part of the tent/canopy)

Applicant Signature

Date

Property Owner Signature

Date

Building Inspector
(If Applicable)

Date

Fire Inspector
(If Applicable)

Date

All inspections must be ready Monday through Friday by 4:00 p.m. Any inspections that have to be done Monday through Friday after 4:00 p.m. will result in a \$50 fee per inspection.

For Town Use Only:

Received by Staff: _____

Payment Received: _____

Town Approval: _____